



# OMEGA CONTROLS PVT. LTD.

CIN : U74900MH2010PTC201754.

JOB NO. 10342223

Dt. 25.06.2022

## TEST CERTIFICATE

CUSTOMER : M/S. FEDERAL ENGINEERS

ORDER NO. : FE/A/0135/2022-23 Dt. 29.04.2022 JOB NO. SP-129

TYPE : SPW41.5M4AKB10

SERIAL NO : 22305

DESCRIPTION : S. S. Punch Grid type 10 Mints rated 4 Steps Resistance Box  
Suitable for MH Motion having HP- 41.5, RV- 305, RA- 62

RESIS. VALUE	OD1/OE1/OF1	D1D2/E1E2/F1F2	D2D3/E2E3/F2F3	D3D/E3E/F3F
	1.91 OHMS	1.00 OHMS	0.51 OHMS	0.41 OHMS

INSULATION RESISTANCE : 50 Megohms

HIGH VOLTAGE TEST : 2000 Volts for 1 minute

TESTED BY: N. H. V.

DATED: 24.06.2022

For OMEGA CONTROLS PVT. LTD

Nitin Harish Vaswani  
Digitally signed by  
Nitin Harish Vaswani  
Date: 2022.06.25  
16:37:17 +05'30'  
Engineer

OFFICE : 1047, BHANDUP IND. ESTATE, LBS MARG, BHANDUP WEST, MUMBAI - 400078, MAHARASHTRA INDIA.  
Phone +91 22 25966741, 25962206, Fax +91 22 25965913, E Mail [info@omegacontrols.co.in](mailto:info@omegacontrols.co.in)

WORKS : PLOT NO.F-14, MIDC, ADDITIONA AMBERNATH, AMBERNATH EAST, MAHARASHTRA 421506 INDIA.  
Phone +91 251 2621486, 2621487, E Mail [works@omegacontrols.co.in](mailto:works@omegacontrols.co.in)





# OMEGA CONTROLS PVT. LTD.

CIN : U74900MH2010PTC201754.

JOB NO. 10342223

Dt. 25.06.2022

## TEST CERTIFICATE

CUSTOMER : M/S. FEDERAL ENGINEERS

ORDER NO. : FE/A/0135/2022-23 Dt. 29.04.2022 JOB NO. SP-129

TYPE : SPW33M4AKB10

SERIAL NO : 22306

DESCRIPTION : S. S. Punch Grid type 10 Mints rated 4 Steps Resistance Box  
Suitable for AH Motion having HP- 33, RV- 280, RA- 53.5

RESIS. VALUE	OD1/OE1/OF1	D1D2/E1E2/F1F2	D2D3/E2E3/F2F3	D3D/E3E/F3F
	1.27 OHMS	1.06 OHMS	0.55 OHMS	0.15 OHMS

INSULATION RESISTANCE : 50 Megohms

HIGH VOLTAGE TEST : 2000 Volts for 1 minute

TESTED BY: N. H. V.

DATED: 24.06.2022

For OMEGA CONTROLS PVT. LTD

Nitin Harish  
Vaswani

Digitally signed by Nitin  
Harish Vaswani  
Date: 2022.06.25  
16:36:17 +05'30'

Engineer

OFFICE : 1047, BHANDUP IND. ESTATE, LBS MARG, BHANDUP WEST, MUMBAI - 400078, MAHARASHTRA INDIA.  
Phone +91 22 25966741, 25962206, Fax +91 22 25965913, E Mail [info@omegacontrols.co.in](mailto:info@omegacontrols.co.in)

WORKS : PLOT NO.F-14, MIDC, ADDITIONA AMBERNATH, AMBERNATH EAST, MAHARASHTRA 421506 INDIA.  
Phone +91 251 2621486, 2621487, E Mail [works@omegacontrols.co.in](mailto:works@omegacontrols.co.in)





# OMEGA CONTROLS PVT. LTD.

CIN : U74900MH2010PTC201754.

JOB NO. 10342223

Dt. 25.06.2022

## TEST CERTIFICATE

CUSTOMER : M/S. FEDERAL ENGINEERS  
ORDER NO. : FE/A/0135/2022-23 Dt. 29.04.2022 JOB NO - SP-129  
TYPE : SPW3.5M4BKB10  
SERIAL NO : 22307  
DESCRIPTION : S. S. Punch Grid type 10 Mints rated 4 Steps Resistance Box  
Suitable for CT Motion having HP- 3.5, RV-115, RA- 13.7

RESIS. VALUE	OD1/OE1/OF1	D1D2/E1E2/F1F2	D2D3/E2E3/F2F3	D3D/E3E/F3F
	2.81 OHMS	2.23 OHMS	1.11 OHMS	0.29 OHMS

INSULATION RESISTANCE: 50 Megohms  
HIGH VOLTAGE TEST : 2000 Volts for 1 minute  
TESTED BY: N. H. V. DATED: 24.06.2022

For OMEGA CONTROLS PVT. LTD

Nitin Harish Vaswani  
Digitally signed by Nitin Harish Vaswani  
Date: 2022.06.25 16:33:32 +05'30'  
Engineer

OFFICE : 1047, BHANDUP IND. ESTATE, LBS MARG, BHANDUP WEST, MUMBAI - 400078, MAHARASHTRA INDIA.  
Phone +91 22 25966741, 25962206, Fax +91 22 25965913, E Mail [info@omegacontrols.co.in](mailto:info@omegacontrols.co.in)

WORKS : PLOT NO.F-14, MIDC, ADDITIONA AMBERNATH, AMBERNATH EAST, MAHARASHTRA 421506 INDIA.  
Phone +91 251 2621486, 2621487, E Mail [works@omegacontrols.co.in](mailto:works@omegacontrols.co.in)





# OMEGA CONTROLS PVT. LTD.

CIN : U74900MH2010PTC201754.

JOB NO. 10342223

Dt. 25.06.2022

## TEST CERTIFICATE

CUSTOMER : **M/S. FEDERAL ENGINEERS**

ORDER NO. : FE/A/0135/2022-23 Dt. 29.04.2022 JOB NO. SP-129

TYPE : SPW9M4BKB10

SERIAL NO : 22308

DESCRIPTION : S. S. Punch Grid type 10 Mints rate 4 Steps Resistance Box  
Suitable for LT Motion having HP- 9, RV- 185, RA- 22

RESIS. VALUE	OD1/OE1/OF1	D1D2/E1E2/F1F2	D2D3/E2E3/F2F3	D3D/E3E/F3F
	6.56 OHMS	2.04 OHMS	0.73 OHMS	0.29 OHMS

INSULATION RESISTANCE: 50 Megohms

HIGH VOLTAGE TEST : 2000 Volts for 1 minute

TESTED BY: N. H. V.

DATED: 24.06.2022

For OMEGA CONTROLS PVT. LTD

**Nitin Harish  
Vaswani**

Digitally signed by  
Nitin Harish Vaswani  
Date: 2022.06.25  
16:35:16 +05'30'

Engineer

OFFICE : 1047, BHANDUP IND. ESTATE, LBS MARG, BHANDUP WEST, MUMBAI - 400078, MAHARASHTRA INDIA.  
Phone +91 22 25966741, 25962206, Fax +91 22 25965913, E Mail [info@omegacontrols.co.in](mailto:info@omegacontrols.co.in)

WORKS : PLOT NO.F-14, MIDC, ADDITIONA AMBERNATH, AMBERNATH EAST, MAHARASHTRA 421506 INDIA.  
Phone +91 251 2621486, 2621487, E Mail [works@omegacontrols.co.in](mailto:works@omegacontrols.co.in)